

# Drinking Water Notice

## AYERSVILLE WATER AND SEWER DISTRICT

### Levels of TTHM above Drinking Water Standards

Our water system recently violated the maximum contaminant level (MCL) for TTHM. The average level of TTHM over the last four quarters for DS201 was 81.2µg/L & DS202 was 81.3µg/L. The standard for TTHM is 80 µg/L.

#### What Should I do?

- **You do not need to use an alternate (e.g. bottled) water supply.** However, if you have specific health concerns, consult your doctor.

#### What does this mean?

The levels detected do not pose an immediate risk to your health. Some people who drink water containing trihalomethanes in excess of MCL over many years may experience problems with their liver, kidneys, or central nervous system, and may have an increased risk of getting cancer.

#### What is being done?

We are investigating and taking the following necessary steps to correct the problem as soon as possible:

1. We are continually working with an engineering firm to identify what could be done on a mechanical level such as aeration or filtration.
2. An aggressive flushing regiment has and will continue to be implemented to keep the standing time to a minimum & to deliver the freshest water possible to our residents.

Additional information may be obtained by contacting:

Contact Person: **Eric Wenzinger 20087068**

Phone Number: **(419) 395-1733**

Mailing Address: **13961 Fruit Ridge Road**

**Defiance, OH 43512**

Please share this information with all other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools and businesses).

You can do this by posting this notice in a public place or distributing copies by hand or mail.

Date Distributed 05/20/2021

PWSID: OH2000903 Facility ID: DS1

Monitoring Period: Second Quarter of 2021